



**Citation and Notification of Penalty**

**Company Name:** South Progress, LLC, dba Fastway Construction, Inc.  
**Inspection Site:** 221 Wisteria Way, Lot 5, Santa Rosa Beach, FL 32459

**Citation 1 Item 1** Type of Violation: **Willful**

29 CFR 1926.501(b)(13): Each employee(s) engaged in residential construction activities 6 feet (1.8 m) or more above lower levels were not protected by guardrail systems, safety net system, or personal fall arrest system:

a. The employer fails to assure effective protection against falls as required by the standard, as demonstrated on October 21, 2015, when employees are working on a residential roof at 221 Wisteria Way Lot 5, Santa Rosa Beach Florida without fall protection and were exposed to 23 feet 6 inch fall hazard.

South Progress, LLC was previously cited for a violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.501(b)(1), which was contained in OSHA inspection number 1076485, citation number 01, item number 02 and was affirmed as a final order on October 19, 2015, with respect to a workplace located at Prominence Phase I North, Santa Rosa Beach, FL 32459.

Fastway Construction, Inc. was previously cited for a violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.501(b)(1), which was contained in OSHA inspection number 999349, citation number 01, item number 01 and was affirmed as a final order on December 15, 2014, with respect to a workplace located at 732 Scenic Gulf Drive, Destin, FL 32541.

Fastway Construction, Inc. was previously cited for a violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.501(b)(13), which was contained in OSHA inspection number 981778, citation number 01, item number 01 and was affirmed as a final order on August 7, 2014, with respect to a workplace located at 106 Blue Sage, Lot 18, Panama City Beach, FL 32413.

Fastway Construction, Inc. was previously cited for a violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.501(b)(13), which was contained in OSHA inspection number 975928, citation number 02, item number 02 and was affirmed as a final order on July 18, 2014, with respect to a workplace located at 104 Blue Sage Rd, Lot 19, Panama City Beach, FL 32459.

Fastway Construction, Inc. was previously cited for a violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.501(b)(13), which was contained in OSHA inspection

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

**U.S. Department of Labor**  
Occupational Safety and Health Administration

**Inspection Number:** 1100315  
**Inspection Date(s):** 10/21/2015 - 10/22/2015  
**Issuance Date:** 03/02/2016



**Citation and Notification of Penalty**

**Company Name:** South Progress, LLC, dba Fastway Construction, Inc.  
**Inspection Site:** 221 Wisteria Way, Lot 5, Santa Rosa Beach, FL 32459

number 951659, citation number 01, item number 02 and was affirmed as a final order on June 6, 2014, with respect to a workplace located at Sheepshank Ln, Lot 160, Santa Rosa Beach, FL 32459.

To abate this violation, the employer must ensure that all employees wear appropriate fall protection when an employee is working at unprotected heights of six feet and more.

Pursuant to 29 CFR 1903.19, the employer must submit documents describing the steps it is taking to ensure compliance, including an explanation of how these steps protect its employees from fall hazards.

**Date By Which Violation Must be Abated:**  
**Proposed Penalty:**

**Corrected During Inspection**  
**\$70,000.00**

A handwritten signature in black ink, appearing to read "B. Sturtecky", written over a horizontal line.

**Brian J. Sturtecky**  
Area Director

**U.S. Department of Labor**  
Occupational Safety and Health Administration  
1851 Executive Center Drive  
Suite 227  
Jacksonville, FL 32207  
Phone: 904-232-2895 Fax: 904-232-1294



## INVOICE / DEBT COLLECTION NOTICE

**Company Name:** South Progress, LLC, dba Fastway Construction, Inc.  
**Inspection Site:** 221 Wisteria Way, Lot 5, Santa Rosa Beach, FL 32459  
**Issuance Date:** 03/02/2016

<b>Summary of Penalties for Inspection Number</b>	<b>1100315</b>
<b>Citation 1, Willful</b>	<b>\$70,000.00</b>
<b>TOTAL PROPOSED PENALTIES</b>	<b>\$70,000.00</b>

To avoid additional charges, please remit payment promptly to this Area Office for the total amount of the uncontested penalties summarized above. Make your check or money order payable to: "DOL-OSHA". Please indicate OSHA's Inspection Number (indicated above) on the remittance. You can also make your payment electronically on [www.pay.gov](http://www.pay.gov). On the left side of the pay.gov homepage, you will see an option to Search Public Forms. Type "OSHA" and click Go. From the results, click on **OSHA Penalty Payment Form**. The direct link is <https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>. You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$25,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will cash the check or money order as if these restrictions or conditions do not exist.

If a personal check is issued, it will be converted into an electronic fund transfer (EFT). This means that our bank will copy your check and use the account information on it to electronically debit your account for the amount of the check. The debit from your account will then usually occur within 24 hours and will be shown on your regular account statement. You will not receive your original check back. The bank will destroy your original check, but will keep a copy of it. If the EFT cannot be completed because of insufficient funds or closed account, the bank will attempt to make the transfer up to 2 times.

Pursuant to the Debt Collection Act of 1982 (Public Law 97-365) and regulations of the U.S. Department of Labor (29 CFR Part 20), the Occupational Safety and Health Administration is required to assess interest, delinquent charges, and administrative costs for the collection of delinquent penalty debts for violations of the Occupational Safety and Health Act.

**Interest:** Interest charges will be assessed at an annual rate determined by the Secretary of the Treasury on all penalty debt amounts not paid within one month (30 calendar days) of the date on which the debt amount becomes due and payable (penalty due date). The current interest rate is one percent (1%). Interest will accrue from the date on which the penalty amounts (as proposed or adjusted) become a final order of the Occupational Safety and Health Review Commission (that is, 15 working days from your receipt of the Citation and Notification of Penalty), unless you file a notice of contest. Interest charges will be waived if the full amount owed is paid within 30 calendar days of the final order.

**Delinquent Charges:** A debt is considered delinquent if it has not been paid within one month (30 calendar days) of the penalty due date or if a satisfactory payment arrangement has not been made. If the debt remains delinquent for more than 90 calendar days, a delinquent charge of six percent (6%) per annum will be assessed accruing from the date that the debt became delinquent.

**Administrative Costs:** Agencies of the Department of Labor are required to assess additional charges for the recovery of delinquent debts. These additional charges are administrative costs incurred by the Agency in its attempt to collect an unpaid debt. Administrative costs will be assessed for demand letters sent in an attempt to collect the unpaid debt.



\_\_\_\_\_  
Brian J. Sturtecky  
Area Director



\_\_\_\_\_  
Date