Occupational Safety and Health Administration 701 Lee Street Suite 950 Des Plaines, IL 60016



# Citation and Notification of Penalty

To:

Goose Lake Construction Inc. and its successors 1645 Birchwood Ave. Des Plaines, IL 60018

Inspection Site: 60 Brentwood Dr. Glencoe, IL 60022

**Inspection Number:** 1418712

**Inspection Date(s)**: 07/25/2019 - 01/13/2020

**Issuance Date**: 01/15/2020

The violation(s) described in this Citation and Notification of Penalty is (are) alleged to have occurred on or about the day(s) the inspection was made unless otherwise indicated within the description given below.

This Citation and Notification of Penalty (this Citation) describes violations of the Occupational Safety and Health Act of 1970. The penalty(ies) listed herein is (are) based on these violations. You must abate the violations referred to in this Citation by the dates listed and pay the penalties proposed, unless within 15 working days (excluding weekends and Federal holidays) from your receipt of this Citation and Notification of Penalty you either call to schedule an informal conference (see paragraph below) or you mail a notice of contest to the U.S. Department of Labor Area Office at the address shown above. Please refer to the enclosed booklet (OSHA 3000) which outlines your rights and responsibilities and which should be read in conjunction with this form. Issuance of this Citation does not constitute a finding that a violation of the Act has occurred unless there is a failure to contest as provided for in the Act or, if contested, unless this Citation is affirmed by the Review Commission or a court.

**Posting** - The law requires that a copy of this Citation and Notification of Penalty be posted immediately in a prominent place at or near the location of the violation(s) cited herein, or, if it is not practicable because of the nature of the employer's operations, where it will be readily observable by all affected employees. This Citation must remain posted until the violation(s) cited herein has (have) been abated, or for 3 working days (excluding weekends and Federal holidays), whichever is longer.

**Informal Conference** - An informal conference is not required. However, if you wish to have such a conference you may request one with the Area Director during the 15 working day contest period by calling 847-227-1700. During such an informal conference you may present any evidence or views which you believe would support an adjustment to the citation(s) and/or penalty(ies).

If you are considering a request for an informal conference to discuss any issues related to this Citation and Notification of Penalty, you must take care to schedule it early enough to allow time to contest after the informal conference, should you decide to do so. Please keep in mind that a written letter of intent to contest must be submitted to the Area Director within 15 working days of your receipt of this Citation. The running of this contest period is not interrupted by an informal conference.

If you decide to request an informal conference, please complete, remove and post the Notice to Employees next to this Citation and Notification of Penalty as soon as the time, date, and place of the informal conference have been determined. Be sure to bring to the conference any and all supporting documentation of existing conditions as well as any abatement steps taken thus far. If conditions warrant, we can enter into an informal settlement agreement which amicably resolves this matter without litigation or contest.

Right to Contest — You have the right to contest this Citation and Notification of Penalty. You may contest all citation items or only individual items. You may also contest proposed penalties and/or abatement dates without contesting the underlying violations. <u>Unless you inform the Area Director in writing that you intend to contest the citation(s) and/or proposed penalty(ies) within 15 working days after receipt, the citation(s) and the proposed penalty(ies) will become a final order of the Occupational Safety and Health Review Commission and may not be reviewed by any court or agency.</u>

**Penalty Payment** – Penalties are due within 15 working days of receipt of this notification unless contested. (See the enclosed booklet and the additional information provided related to the Debt Collection Act of 1982.) Make your check or money order payable to "DOL-OSHA". Please indicate the Inspection Number on the remittance. You can also make your payment electronically on <a href="www.pay.gov">www.pay.gov</a>. On the left side of the pay.gov homepage, you will see an option to Search Public Forms. Type "**OSHA**" and click Go. From the results, click on **OSHA Penalty Payment Form**. The direct link is:

#### https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334.

You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$25,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will process the payments as if these restrictions or conditions do not exist.

**Notification of Corrective Action** – For each violation which you do not contest, you must provide *abatement certification* to the Area Director of the OSHA office issuing the citation and identified above. This abatement certification is to be provided by letter within 10 calendar days after each abatement date. Abatement certification includes the date and method of abatement. If the citation indicates that the violation was corrected during the inspection, no abatement certification is required for that item. The abatement certification letter must be posted at the location where the violation appeared and the corrective action took place or employees must otherwise be effectively informed about abatement activities. A sample abatement certification letter is enclosed with this Citation. In addition, where the citation indicates that *abatement documentation* is necessary, evidence of the purchase or repair of equipment, photographs or video, receipts, training records, etc., verifying that abatement has occurred is required to be provided to the Area Director.

Employer Discrimination Unlawful – The law prohibits discrimination by an employer against an

employee for filing a complaint or for exercising any rights under this Act. An employee who believes that he/she has been discriminated against may file a complaint no later than 30 days after the discrimination occurred with the U.S. Department of Labor Area Office at the address shown above.

Employer Rights and Responsibilities – The enclosed booklet (OSHA 3000) outlines additional employer rights and responsibilities and should be read in conjunction with this notification.

**Notice to Employees** – The law gives an employee or his/her representative the opportunity to object to any abatement date set for a violation if he/she believes the date to be unreasonable. The contest must be mailed to the U.S. Department of Labor Area Office at the address shown above and postmarked within 15 working days (excluding weekends and Federal holidays) of the receipt by the employer of this Citation and Notification of Penalty.

**Inspection Activity Data** – You should be aware that OSHA publishes information on its inspection and citation activity on the Internet under the provisions of the Electronic Freedom of Information Act. The information related to these alleged violations will be posted when our system indicates that you have received this citation. You are encouraged to review the information concerning your establishment at www.osha.gov. If you have any dispute with the accuracy of the information displayed, please contact this office.

# U.S. Department of Labor Occupational Safety and Health Administration



# NOTICE TO EMPLOYEES OF INFORMAL CONFERENCE

An informal conference has been scheduled with OSHA to discuss the citation(s) issued on			
01/15/2020. The conference will be held by telephone	or at the OSHA office lo	ocated at 701 Lee	
Street, Suite 950, Des Plaines, IL 60016 on	at	· · ·	
Employees and/or representatives of employees have	a right to attend an infor	mal conference.	

#### CERTIFICATION OF CORRECTIVE ACTION WORKSHEET

**Inspection Number: 1418712** 

Company Name: Goose Lake Construction Inc.

Inspection Site: 60 Brentwood Dr., Glencoe, IL 60022

Issuance Date: 01/15/2020

List the specific method of correction for each item on this citation in this package that does not read "Corrected During Inspection" and return to: U.S. Department of Labor – Occupational Safety and Health Administration, 701 Lee Street, Suite 950, Des Plaines, IL 60016.

Citation Number	and Item Number	was corrected on	
By (Method of Abate)	ment):		
Citation Number	and Item Number	was corrected on	
By (Method of Abater	ment):	Was corrected on	
	4		•
Citation Number	and Item Number	was corrected on	
by (Memod of Abate)			
·	•		
Citation Number	and Item Number	was corrected on	
By (Method of Abate)	ment):		
*			
Citation Number	and Item Number	was corrected on	
By (Method of Abater	nent):		
Citation Number	and Item Number	was corrected on	
By (Method of Abater			
I contify that the inform	mation contained in this	do comment is a converte and that the affected and 1	
	een informed of the aba	document is accurate and that the affected emplo	oyees and their
representatives have a	· ·	emont.	
	•		
Signature		Date	
Typed or Printed Name		Title	

**NOTE: 29 USC 666(g)** whoever knowingly makes any false statements, representation or certification in any application, record, plan or other documents filed or required to be maintained pursuant to the Act shall, upon conviction, be punished by a fine of not more than \$10,000 or by imprisonment of not more than 6 months or both.

POSTING: A copy of completed Corrective Action Worksheet should be posted for employee review.

Occupational Safety and Health Administration Inspection Date(s): 07/25/2019 - 01/13/2020

**Inspection Number:** 1418712

**Issuance Date:** 01/15/2020



#### Citation and Notification of Penalty

Company Name: Goose Lake Construction Inc. **Inspection Site:** 60 Brentwood Dr., Glencoe, IL 60022

# Citation 1 Item 1 Type of Violation: **Serious**

29 CFR 1926.21(b)(2): The employer did not instruct each employee in the recognition and avoidance of unsafe conditions and the regulations applicable to his/her environment to control or eliminate any hazards or other exposure to illness or injury:

a) On or about July 24, 2019, the employer did not instruct each employee in the recognition, avoidance and control of the hazardous conditions associated with the trenching and excavation work.

In accordance with 29 CFR 1903.19(d), abatement certification is required for this violation (using the CERTIFICATION OF CORRECTIVE ACTION WORKSHEET), and in addition, documentation demonstrating that abatement is complete must be included with your certification. This documentation may include, but is not limited to, evidence of the purchase or repair of the equipment, photographic or video evidence of abatement, or other written records.

02/19/2020 Date By Which Violation Must be Abated: Proposed Penalty: \$13,260.00

Occupational Safety and Health Administration Inspection Date(s): 07/25/2019 - 01/13/2020

**Inspection Number:** 1418712

**Issuance Date:** 01/15/2020



#### Citation and Notification of Penalty

Company Name: Goose Lake Construction Inc. Inspection Site: 60 Brentwood Dr., Glencoe, IL 60022

# Citation 1 Item 2 Type of Violation: Serious

29 CFR 1926.651(c)(2): A stairway, ladder, ramp or other safe means of egress was not located in trench excavations that were 4 feet (1.22 m) or more in depth so as to require no more than 25 feet (7.62 m) of lateral travel for employees:

a) On or about July 24, 2019, an employee was not provided with a safe means of egress when working in a trench excavation with a depth of approximately 7.6 feet.

In accordance with 29 CFR 1903.19(c), abatement certification is required for this violation (using the CERTIFICATION OF CORRECTIVE ACTION WORKSHEET).

Date By Which Violation Must be Abated: Proposed Penalty:

01/22/2020

\$12,503.00

Occupational Safety and Health Administration Inspection Date(s): 07/25/2019 - 01/13/2020

**Inspection Number:** 1418712

**Issuance Date:** 01/15/2020



#### Citation and Notification of Penalty

Company Name: Goose Lake Construction Inc. Inspection Site: 60 Brentwood Dr., Glencoe, IL 60022

Citation 1 Item 3 Type of Violation: **Serious** 

29 CFR 1926.651(j)(2): Protection was not provided by placing and keeping excavated or other materials or equipment at least 2 feet (.61m) from the edge of excavations, or by the use of retaining devices that were sufficient to prevent materials or equipment from falling or rolling into excavations, or by a combination of both if necessary:

a) On or about July 24, 2019, an employee was not protected from the hazard of falling or rolling excavated material that was placed and kept at the edge of the trench excavation.

In accordance with 29 CFR 1903.19(c), abatement certification is required for this violation (using the CERTIFICATION OF CORRECTIVE ACTION WORKSHEET).

Date By Which Violation Must be Abated: Proposed Penalty:

01/22/2020

\$12,503.00

Occupational Safety and Health Administration Inspection Date(s): 07/25/2019 - 01/13/2020

**Inspection Number:** 1418712

**Issuance Date: 01/15/2020** 



#### Citation and Notification of Penalty

**Company Name:** Goose Lake Construction Inc. Inspection Site: 60 Brentwood Dr., Glencoe, IL 60022

# Citation 2 Item 1 Type of Violation: Repeat

29 CFR 1926.100(a): Employees were not protected by protective helmets while working in areas where there was a possible danger of head injury from impact, or from falling or flying objects, or from electrical shock and burns:

The employer does not protect each employee in its trench excavation by requiring the employee to wear protective helmet when working in a trench excavation where there are possible dangers of head injury from impact or from falling objects.

a) This violation was most recently observed on or about July 24, 2019, at 60 Brentwood Dr., Glencoe, Illinois. An employee working in a trench excavation was not wearing protective helmet where there were possible dangers of head injury from impact or falling objects.

Goose Lake Construction Inc., was previously cited for a violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.100(a), which was contained in OSHA inspection number 1317957, citation number 3, item number 1 and was affirmed as a final order on November 19, 2018, with respect to a workplace located at 6001 Capulina Ave., Morton Grove, Illinois 60053.

Goose Lake Construction Inc., was previously cited for a violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.100(a), which was contained in OSHA inspection number 1189653, citation number 1, item number 2 and was affirmed as a final order on December 13, 2016, with respect to a workplace located at 374 Lee St., Des Plaines, Illinois 60016.

Goose Lake Construction Inc., was previously cited for a violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.100(a), which was contained in OSHA inspection number 1162229, citation number 1, item number 2 and was affirmed as a final order on August 15, 2016, with respect to a workplace located at 2515 W. Lawrence Ave., Chicago, Illinois 60606.

To abate this hazard in the future, the employer must ensure that each employee is provided with a hard hat while working in a trench excavation where there are possible dangers of head injury from impact

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

Occupational Safety and Health Administration Inspection Date(s): 07/25/2019 - 01/13/2020

**Inspection Number:** 1418712

**Issuance Date:** 01/15/2020



#### Citation and Notification of Penalty

Company Name: Goose Lake Construction Inc. Inspection Site: 60 Brentwood Dr., Glencoe, IL 60022

or falling objects.

Pursuant to 29 CFR 1903.19, the employer must submit documents describing the steps it is taking to ensure compliance, including an explanation of how these steps protect each employee from head injury while working in a trench excavation.

Date By Which Violation Must be Abated: Proposed Penalty:

01/22/2020

\$62,513.00

Occupational Safety and Health Administration Inspection Date(s): 07/25/2019 - 01/13/2020

**Inspection Number:** 1418712

**Issuance Date:** 01/15/2020



#### Citation and Notification of Penalty

Company Name: Goose Lake Construction Inc. Inspection Site: 60 Brentwood Dr., Glencoe, IL 60022

# Citation 2 Item 2 Type of Violation: **Repeat**

29 CFR 1926.652(a)(1): Each employee in an excavation was not protected from cave-ins by an adequate protective system designed in accordance with 29 CFR 1926.652(b) or 1926.652(c):

The employer does not protect each employee in its trench excavation by properly sloping the excavation or by using appropriate protective systems designed in accordance with paragraphs (b) or (c) of 29 CFR 1926.652.

a) This violation was most recently observed on or about July 24, 2019, at 60 Brentwood Dr., Glencoe, Illinois. Employees were not protected from the hazard of cave-in while working in a trench excavation measuring approximately 7.6 feet in depth.

Goose Lake Construction Inc., was previously cited for a violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.652(a)(1), which was contained in OSHA inspection number 1317957, citation number 2, item number 1 and was affirmed as a final order on November 19, 2018, with respect to a workplace located at 6001 Capulina Ave., Morton Grove, Illinois 60053.

Goose Lake Construction Inc., was previously cited for a violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.652(a)(1), which was contained in OSHA inspection number 1315544, citation number 1, item number 1 and was affirmed as a final order on November 19, 2018, with respect to a workplace located at 921 Pleasant Ln., Glenview, Illinois 60025.

Goose Lake Construction Inc., was previously cited for a violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.652(a)(1), which was contained in OSHA inspection number 1162229, citation number 1, item number 3 and was affirmed as a final order on August 15, 2016, with respect to a workplace located at 2515 W Lawrence Ave., Chicago, Illinois 60606.

To abate this hazard in the future, the employer must ensure that it's excavations are properly sloped, or that protective systems designed in accordance with this standard are used, and that no employees enter the excavations until protection is provided.

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

Occupational Safety and Health Administration Inspection Date(s): 07/25/2019 - 01/13/2020

**Inspection Number:** 1418712

**Issuance Date:** 01/15/2020



#### **Citation and Notification of Penalty**

Company Name: Goose Lake Construction Inc. Inspection Site: 60 Brentwood Dr., Glencoe, IL 60022

Pursuant to 29 CFR 1903.19, the employer must submit documents describing the steps it is taking to ensure compliance, including an explanation of how these steps protect it's employees from excavation cave-ins

Date By Which Violation Must be Abated: Proposed Penalty:

01/22/2020 \$132,598.00

**Angeline Loftus** Area Director

Occupational Safety and Health Administration 701 Lee Street Suite 950 Des Plaines, IL 60016



# INVOICE / DEBT COLLECTION NOTICE

**Company Name:** 

Goose Lake Construction Inc.

**Inspection Site:** 

60 Brentwood Dr., Glencoe, IL 60022

**Issuance Date:** 

01/15/2020

**Summary of Penalties for Inspection Number** 

1418712

Citation 1, Serious

\$38,266.00

Citation 2, Repeat

\$195,111.00

TOTAL PROPOSED PENALTIES

\$233,377.00

To avoid additional charges, please remit payment promptly to this Area Office for the total amount of the uncontested penalties summarized above. Make your check or money order payable to: "DOL-OSHA". Please indicate OSHA's Inspection Number (indicated above) on the remittance. You can also make your payment electronically on <a href="https://www.pay.gov">www.pay.gov</a>. On the left side of the pay.gov homepage, you will see an option to Search Public Forms. Type "OSHA" and click Go. From the results, click on <a href="https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334">OSHA Penalty Payment Form</a>. The direct link is <a href="https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334">https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334</a>. You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$25,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will cash the check or money order as if these restrictions or conditions do not exist.

If a personal check is issued, it will be converted into an electronic fund transfer (EFT). This means that our bank will copy your check and use the account information on it to electronically debit your account for the amount of the check. The debit from your account will then usually occur within 24 hours and will be shown on your regular account statement. You will not receive your original check back. The bank will destroy your original check, but will keep a copy of it. If the EFT cannot be completed because of insufficient funds or closed

account, the bank will attempt to make the transfer up to 2 times.

Pursuant to the Debt Collection Act of 1982 (Public Law 97-365) and regulations of the U.S. Department of Labor (29 CFR Part 20), the Occupational Safety and Health Administration is required to assess interest, delinquent charges, and administrative costs for the collection of delinquent penalty debts for violations of the Occupational Safety and Health Act.

<u>Interest</u>: Interest charges will be assessed at an annual rate determined by the Secretary of the Treasury on all penalty debt amounts not paid within one month (30 calendar days) of the date on which the debt amount becomes due and payable (penalty due date). The current interest rate is one percent (1%). Interest will accrue from the date on which the penalty amounts (as proposed or adjusted) become a final order of the Occupational Safety and Health Review Commission (that is, 15 working days from your receipt of the Citation and Notification of Penalty), unless you file a notice of contest. Interest charges will be waived if the full amount owed is paid within 30 calendar days of the final order.

<u>Delinquent Charges</u>: A debt is considered delinquent if it has not been paid within one month (30 calendar days) of the penalty due date or if a satisfactory payment arrangement has not been made. If the debt remains delinquent for more than 90 calendar days, a delinquent charge of six percent (6%) per annum will be assessed accruing from the date that the debt became delinquent.

Administrative Costs: Agencies of the Department of Labor are required to assess additional charges for the recovery of delinquent debts. These additional charges are administrative costs incurred by the Agency in its attempt to collect an unpaid debt. Administrative costs will be assessed for demand letters sent in an attempt to collect the unpaid debt.

Angeline Loftus

Area Director

January 15, 2020