

**U.S. Department of Labor** Occupational Safety and Health Administration  
100 N. Summit Street  
Suite 100  
Toledo, OH 43604



12/08/2022

Mike Krueger, dba Altogether Roofing, LLC  
and its successors  
861 Main Street  
Martin, OH 43445

Dear Employer:

Enclosed you will find citations for violations of the Occupational Safety and Health Act of 1970 (the Act) which may have accompanying proposed penalties. Also enclosed is a booklet entitled, "Employer Rights and Responsibilities Following an OSHA Inspection", (OSHA 3000-04R) revised 2018, which explains your rights and responsibilities under the Act. If you have any questions about the enclosed citations and penalties, I would welcome further discussions in person or by telephone. Please contact me at (419) 259-7542.

You will note on page 6 of the booklet that, for violations which you do not contest, you must (1) notify this office promptly by letter that you have taken appropriate corrective action within the time set forth on the citation; and (2) pay any penalties assessed. Please inform me of the abatement steps you have taken and of their dates together with adequate supporting documentation; e.g., drawings or photographs of corrected conditions, purchase/work orders related to abatement actions, air sampling results. This information will allow us to close the case.


As indicated on page 3 of the booklet, you may request an informal conference with me during the 15-working-day notice of contest period. During such an informal conference you may present any evidence or views which you believe would support an adjustment to the citation or the penalty.

If you are considering a request for an informal conference to discuss any issues related to this Citation and Notification of Penalty, you must take care to schedule it early enough to allow time to contest after the informal conference, should you decide to do so. Please keep in mind that a written letter of intent to contest must be submitted to the Area Director within 15 working days of your receipt of the citation. The running of this contest period is not interrupted by an informal conference.

If you decide to request an informal conference, please complete the attached notice at the bottom of this letter and post it next to the Citations as soon as the time, date and the place of the informal conference have been determined. Be sure to bring to the conference with you any and all supporting documentation of existing conditions as well as of any abatement steps taken thus far. If conditions warrant, we can enter into an informal settlement agreement which amicably resolves this matter without litigation or contest.

You should be aware that OSHA publishes information on its inspection and citation activity on the Internet under the provisions of Electronic Freedom of Information Act. The information related to these alleged violations will be posted when our system indicates that you have received this citation. You are encouraged to review the information concerning your establishment at [www.osha.gov](http://www.osha.gov). If you have any dispute with the accuracy of the information displayed, please contact this office.

Sincerely,



For

**Todd Jensen**  
Area Director

Enclosures

**U.S. Department of Labor**  
Occupational Safety and Health Administration  
100 N. Summit Street  
Suite 100  
Toledo, OH 43604



## Citation and Notification of Penalty

**To:**  
Mike Krueger, dba Altogether Roofing, LLC  
and its successors  
861 Main Street  
Martin, OH 43445

**Inspection Number:** 1603544  
**Inspection Date(s):** 06/22/2022 - 06/22/2022  
**Issuance Date:** 12/08/2022

**Inspection Site:**  
3359 Stonebrooke Ln.  
Maumee, OH 43537

*The violation(s) described in this Citation and Notification of Penalty is (are) alleged to have occurred on or about the day(s) the inspection was made unless otherwise indicated within the description given below.*

This Citation and Notification of Penalty (this Citation) describes violations of the Occupational Safety and Health Act of 1970. The penalty(ies) listed herein is (are) based on these violations. You must abate the violations referred to in this Citation by the dates listed and pay the penalties proposed, unless within 15 working days (excluding weekends and Federal holidays) from your receipt of this Citation and Notification of Penalty **you either call to schedule an informal conference (see paragraph below) or** you mail a notice of contest to the U.S. Department of Labor Area Office at the address shown above. Please refer to the enclosed booklet (OSHA 3000) which outlines your rights and responsibilities and which should be read in conjunction with this form. Issuance of this Citation does not constitute a finding that a violation of the Act has occurred unless there is a failure to contest as provided for in the Act or, if contested, unless this Citation is affirmed by the Review Commission or a court.

**Posting** - The law requires that a copy of this Citation and Notification of Penalty be posted immediately in a prominent place at or near the location of the violation(s) cited herein, or, if it is not practicable because of the nature of the employer's operations, where it will be readily observable by all affected employees. This Citation must remain posted until the violation(s) cited herein has (have) been abated, or for 3 working days (excluding weekends and Federal holidays), whichever is longer.

**Informal Conference** - An informal conference is not required. However, if you wish to have such a conference you may request one with the Area Director during the 15 working day contest period by calling (419) 259-7542. During such an informal conference, you may present any evidence or views which you believe would support an adjustment to the citation(s) and/or penalty(ies).

If you are considering a request for an informal conference to discuss any issues related to this Citation and Notification of Penalty, you must take care to schedule it early enough to allow time to contest after the informal conference, should you decide to do so. Please keep in mind that a written letter of intent to contest must be submitted to the Area Director within 15 working days of your receipt of this Citation. The running of this contest period is not interrupted by an informal conference.

If you decide to request an informal conference, please complete, remove and post the Notice to Employees next to this Citation and Notification of Penalty as soon as the time, date, and place of the informal conference have been determined. Be sure to bring to the conference any and all supporting documentation of existing conditions as well as any abatement steps taken thus far. If conditions warrant, we can enter into an informal settlement agreement which amicably resolves this matter without litigation or contest.

**Right to Contest** – You have the right to contest this Citation and Notification of Penalty. You may contest all citation items or only individual items. You may also contest proposed penalties and/or abatement dates without contesting the underlying violations. **Unless you inform the Area Director in writing that you intend to contest the citation(s) and/or proposed penalty(ies) within 15 working days after receipt, the citation(s) and the proposed penalty(ies) will become a final order of the Occupational Safety and Health Review Commission and may not be reviewed by any court or agency.**

**Penalty Payment** – Penalties are due within 15 working days of receipt of this notification unless contested. (See the enclosed booklet and the additional information provided related to the Debt Collection Act of 1982.) Make your check or money order payable to “DOL-OSHA”. Please indicate the Inspection Number on the remittance. You can also make your payment electronically at [www.pay.gov](http://www.pay.gov). At the top of the [pay.gov](http://www.pay.gov) homepage, type "OSHA" in the Search field and select Search. From **OSHA Penalty Payment Form** search result, select Continue. The direct link is:

<https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>

You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$25,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will process the payments as if these restrictions or conditions do not exist.

**Notification of Corrective Action** – For each violation which you do not contest, you must provide **abatement certification** to the Area Director of the OSHA office issuing the citation and identified above. This abatement certification is to be provided by letter within 10 calendar days after each abatement date. Abatement certification includes the date and method of abatement. If the citation indicates that the violation was corrected during the inspection, no abatement certification is required for that item. The abatement certification letter must be posted at the location where the violation appeared and the corrective action took place or employees must otherwise be effectively informed about abatement activities. A sample abatement certification letter is enclosed with this Citation. In addition, where the citation indicates that **abatement documentation** is necessary, evidence of the purchase or repair of equipment, photographs or video, receipts, training records, etc., verifying that abatement has occurred is required to be provided to the Area Director.

**Employer Discrimination Unlawful** – The law prohibits discrimination by an employer against an

employee for filing a complaint or for exercising any rights under this Act. An employee who believes that he/she has been discriminated against may file a complaint no later than 30 days after the discrimination occurred with the U.S. Department of Labor Area Office at the address shown above.

**Employer Rights and Responsibilities** – The enclosed booklet (OSHA 3000) outlines additional employer rights and responsibilities and should be read in conjunction with this notification.

**Notice to Employees** – The law gives an employee or his/her representative the opportunity to object to any abatement date set for a violation if he/she believes the date to be unreasonable. The contest must be mailed to the U.S. Department of Labor Area Office at the address shown above and postmarked within 15 working days (excluding weekends and Federal holidays) of the receipt by the employer of this Citation and Notification of Penalty.

**Inspection Activity Data** – You should be aware that OSHA publishes information on its inspection and citation activity on the Internet under the provisions of the Electronic Freedom of Information Act. The information related to these alleged violations will be posted when our system indicates that you have received this citation. You are encouraged to review the information concerning your establishment at [www.osha.gov](http://www.osha.gov). If you have any dispute with the accuracy of the information displayed, please contact this office.



## NOTICE TO EMPLOYEES OF INFORMAL CONFERENCE

An informal conference has been scheduled with OSHA to discuss the citation(s) issued on 12/08/2022. The conference will be held by telephone or at the OSHA office located at 100 N. Summit Street, Suite 100, Toledo, OH 43604 on \_\_\_\_\_ at \_\_\_\_\_.

Employees and/or representatives of employees have a right to attend an informal conference.

**CERTIFICATION OF CORRECTIVE ACTION WORKSHEET**

**Inspection Number: 1603544**

Company Name: Mike Krueger, dba Altogether Roofing, LLC  
Inspection Site: 3359 Stonebrooke Ln., Maumee, OH 43537  
Issuance Date: 12/08/2022

List the specific method of correction for each item on this citation in this package that does not read "Corrected During Inspection" and return to: **U.S. Department of Labor – Occupational Safety and Health Administration, 100 N. Summit Street, Suite 100, Toledo, OH 43604.**

Citation Number \_\_\_\_\_ and Item Number \_\_\_\_\_ was corrected on \_\_\_\_\_  
By (Method of Abatement): \_\_\_\_\_  
\_\_\_\_\_

Citation Number \_\_\_\_\_ and Item Number \_\_\_\_\_ was corrected on \_\_\_\_\_  
By (Method of Abatement): \_\_\_\_\_  
\_\_\_\_\_

Citation Number \_\_\_\_\_ and Item Number \_\_\_\_\_ was corrected on \_\_\_\_\_  
By (Method of Abatement): \_\_\_\_\_  
\_\_\_\_\_

Citation Number \_\_\_\_\_ and Item Number \_\_\_\_\_ was corrected on \_\_\_\_\_  
By (Method of Abatement): \_\_\_\_\_  
\_\_\_\_\_

Citation Number \_\_\_\_\_ and Item Number \_\_\_\_\_ was corrected on \_\_\_\_\_  
By (Method of Abatement): \_\_\_\_\_  
\_\_\_\_\_

Citation Number \_\_\_\_\_ and Item Number \_\_\_\_\_ was corrected on \_\_\_\_\_  
By (Method of Abatement): \_\_\_\_\_  
\_\_\_\_\_

I certify that the information contained in this document is accurate and that the affected employees and their representatives have been informed of the abatement.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

\_\_\_\_\_  
Typed or Printed Name

\_\_\_\_\_  
Title

**NOTE: 29 USC 666(g)** whoever knowingly makes any false statements, representation or certification in any application, record, plan or other documents filed or required to be maintained pursuant to the Act shall, upon conviction, be punished by a fine of not more than \$10,000 or by imprisonment of not more than 6 months or both.

**POSTING:** A copy of completed Corrective Action Worksheet should be posted for employee review



**Citation and Notification of Penalty**

**Company Name:** Mike Krueger, dba Altogether Roofing, LLC  
**Inspection Site:** 3359 Stonebrooke Ln., Maumee, OH 43537

---

Citation 1 Item 1 Type of Violation: **Serious**

29 CFR 1926.1060(a):The employer did not provide a training program for each employee using ladders and stairways, as necessary, which would enable each employee to recognize hazards related to ladders and stairways and train each employee in the procedures to be followed to minimize these hazards:

On or about June 22, 2022 the employer Mike Krueger dba Altogether Roofing, LLC at jobsite located at 3359 Stonebrooke Ln. Maumee OH, 43537 did not provide a training program for each employee potentially exposed to fall hazards while using a portable ladder to enable each employee to recognize the hazards of falling from the ladder and the procedures to be followed in order to minimize these hazards. Eight employees using three aluminum extension ladders to access the roof to perform roofing work were exposed to fall hazards 12 feet or greater to the ground below.

In accordance with 29 CFR 1903.19(d), abatement certification is required for this violation (using the CERTIFICATION OF CORRECTIVE ACTION WORKSHEET), and in addition, documentation demonstrating that abatement is complete must be included with your certification. This documentation may include, but is not limited to, evidence of the purchase or repair of the equipment, photographic or video evidence, or written records.

**ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM**

Date By Which Violation Must be Abated:	December 27, 2022
Proposed Penalty:	\$4,786.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.





## **Citation and Notification of Penalty**

**Company Name:** Mike Krueger, dba Altogether Roofing, LLC  
**Inspection Site:** 3359 Stonebrooke Ln., Maumee, OH 43537

---

The alleged violations below have been grouped because they involve similar or related hazards that may increase the potential for injury or illness.

### **Citation 2 Item 1 a** Type of Violation: **Willful - Serious**

29 CFR 1926.20(b)(1): The employer does not initiate and maintain accident prevention programs as necessary to comply with this part:

Mike Krueger dba Altogether Roofing LLC. does not maintain a plan or a program for fall protection and training requirements to identify job site hazards which assists employees in maintaining a safe working environment. Such programs would support the employer and employees in identifying and avoiding potential hazards such as falls and struck by hazards during job site operations, decreasing the probability of employee injury or illness. This violation was most recently observed on or about June 22, 2022 at a jobsite located at 3359 Stonebrooke Ln. Maumee OH, 43537.

To abate this violation, the employer must provide evidence demonstrating that appropriate safety and health programs have been implemented avoid fall hazards on its worksites.

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.20(b)(1)), which was contained in OSHA Inspection #1477543, Citation number 1, Item number 1a, and was affirmed as a final order on December 23, 2020, with respect to a workplace located at 4840 Waterville Monclova Road, Monclova, Ohio.

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.20(b)(1)), which was contained in OSHA Inspection #1399714, Citation number 3, Item number 1a, and was affirmed as a final order on November 7, 2019, with respect to a workplace located at 25368 Fox Hunt Drive in Perrysburg, Ohio.

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.20(b)(1)), which was contained in OSHA Inspection #1393708, Citation number 1, Item number 1a, and was affirmed as a final order on November 8, 2019, with respect to a workplace located at 726 Overland Parkway in Toledo, Ohio.

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.20(b)(1)), which was contained in OSHA Inspection #1265476, Citation number 1, Item number 1a, and was affirmed as a final order on February 13, 2018, with respect to a workplace located at 3436 Bayberry Place in Oregon, Ohio.

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



**Citation and Notification of Penalty**

**Company Name:** Mike Krueger, dba Altogether Roofing, LLC  
**Inspection Site:** 3359 Stonebrooke Ln., Maumee, OH 43537

---

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.20(b)(1)), which was contained in OSHA Inspection #1257585, Citation number 2, Item number 1, and was affirmed as a final order on November 6, 2017, with respect to a workplace located at 2638 Spring Water Drive in Toledo, Ohio.

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.20(b)(1)), which was contained in OSHA Inspection #1229800, Citation number 2, Item number 1a, and was affirmed as a final order on January 24, 2018, with respect to a workplace located at 9520 Jerusalem Road in Curtice, Ohio.

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.20(b)(1)), which was contained in OSHA Inspection #1177422, Citation number 2, Item number 1, and was affirmed as a final order on March 3, 2017, with respect to a workplace located at 10429 White Oak Drive in Perrysburg, Ohio.

In accordance with 29 CFR 1903.19(d), abatement certification is required for this violation (using the CERTIFICATION OF CORRECTIVE ACTION WORKSHEET), and in addition, documentation demonstrating that abatement is complete must be included with your certification. This documentation may include, but is not limited to, evidence of the purchase or repair of the equipment, photographic or video evidence, or written records.

**ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM**

Date By Which Violation Must be Abated:	December 27, 2022
Proposed Penalty:	\$95,718.00



## **Citation and Notification of Penalty**

**Company Name:** Mike Krueger, dba Altogether Roofing, LLC  
**Inspection Site:** 3359 Stonebrooke Ln., Maumee, OH 43537

---

### **Citation 2 Item 1 b** Type of Violation: **Willful - Serious**

29 CFR 1926.503(a)(1): The employer does not provide a training program for each employee potentially exposed to fall hazards to enable each employee to recognize the hazards of falling and the procedures to be followed in order to minimize these hazards:

Mike Krueger dba Altogether Roofing, LLC, does not ensure a fall protection training program is in place to enable each employee to recognize the hazards of falling, and procedures to minimize these hazards. Such programs would support the employer and employees in identifying and avoiding potential hazards such as falls during job site operations, decreasing the probability of employee injury or illness. This violation was most recently observed on or about June 22, 2022 at a jobsite located at 3359 Stonebrooke Ln. Maumee OH, 43537.

To abate this citation, the employer must provide evidence that fall protection training has been provided to its employees.

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.503(a)(1)), which was contained in OSHA Inspection #1477543, Citation number 1, Item number 1b, and was affirmed as a final order on December 23, 2020, with respect to a workplace located at 4840 Waterville Monclova Road, Monclova, Ohio.

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.503(a)(1)), which was contained in OSHA Inspection #1399714, Citation number 3, Item number 1b, and was affirmed as a final order on November 7, 2019, with respect to a workplace located at 25368 Fox Hunt Drive in Perrysburg, Ohio.

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.503(a)(1)), which was contained in OSHA Inspection #1393708, Citation number 1, Item number 1b, and was affirmed as a final order on November 8, 2019, with respect to a workplace located at 726 Overland Parkway in Toledo, Ohio.

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.503(a)(1)), which was contained in OSHA Inspection #1265476, Citation number 1, Item number 1b, and was affirmed as a final order on February 13, 2018, with respect to a workplace located at 3436 Bayberry Place in Oregon, Ohio.

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



**Citation and Notification of Penalty**

**Company Name:** Mike Krueger, dba Altogether Roofing, LLC  
**Inspection Site:** 3359 Stonebrooke Ln., Maumee, OH 43537

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.503(a)(1)), which was contained in OSHA Inspection #1257585, Citation number 2, Item number 2, and was affirmed as a final order on November 6, 2017, with respect to a workplace located at 2638 Spring Water Drive in Toledo, Ohio.

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.503(a)(1)), which was contained in OSHA Inspection #1229800, Citation number 1, Item number 1b, and was affirmed as a final order on January 24, 2018, with respect to a workplace located at 9520 Jerusalem Road in Curtice, Ohio.

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.503(a)(1)), which was contained in OSHA Inspection #1177422, Citation number 2, Item number 2b, and was affirmed as a final order on March 3, 2017, with respect to a workplace located at 10429 White Oak Drive in Perrysburg, Ohio.

In accordance with 29 CFR 1903.19(d), abatement certification is required for this violation (using the CERTIFICATION OF CORRECTIVE ACTION WORKSHEET), and in addition, documentation demonstrating that abatement is complete must be included with your certification. This documentation may include, but is not limited to, evidence of the purchase or repair of the equipment, photographic or video evidence, or written records.

**ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM**

Date By Which Violation Must be Abated:	December 27, 2022
Proposed Penalty:	\$0.00



## **Citation and Notification of Penalty**

**Company Name:** Mike Krueger, dba Altogether Roofing, LLC  
**Inspection Site:** 3359 Stonebrooke Ln., Maumee, OH 43537

---

### **Citation 2 Item 2**    Type of Violation: **Willful - Serious**

29 CFR 1926.501(b)(13): Each employee(s) engaged in residential construction activities 6 feet (1.8 m) or more above lower levels are not protected by guardrail systems, safety net system, or personal fall arrest system, nor were employee(s) provided with an alternative fall protection measure under another provision of paragraph 1926.501 (b):

Mike Krueger dba Altogether Roofing LLC., does not ensure employees were protected from falls while conducting residential roofing construction activities on the second (roof) level of a residential single family home, while exposed to a fall of approximately 20 feet or greater to the ground below. This violation was most recently observed on or about June 22, 2022 at a jobsite located at 3359 Stonebrooke Ln. Maumee OH, 43537.

To abate this citation, the employer must demonstrate that fall protection is provided and being used by its employees when working more than 6 feet from the lower level.

Mike Krueger dba Altogether Roofing, LLC, was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.503(b)(13)), which was contained in OSHA Inspection #1477543, Citation number 1, Item number 1b, and was affirmed as a final order on December 23, 2020, with respect to a workplace located at 4840 Waterville Monclova Road, Monclova, Ohio.

Mike Krueger dba Altogether Roofing, LLC, was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.501(b)(13)), which was contained in OSHA Inspection #1399714, Citation number 3, Item number 2, and was affirmed as a final order on November 7, 2019, with respect to a workplace located at 25368 Fox Hunt Drive in Perrysburg, Ohio.

Mike Krueger dba Altogether Roofing, LLC, was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.501(b)(13)), which was contained in OSHA Inspection #1393708, Citation number 1, Item number 2, and was affirmed as a final order on November 8, 2019, with respect to a workplace located at 726 Overland Parkway in Toledo, Ohio.

Mike Krueger dba Altogether Roofing, LLC, was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.501(b)(13)), which was contained in OSHA Inspection #1265476, Citation number 1, Item number 2, and was affirmed as a final order on February 13, 2018, with respect to a workplace located at 3436 Bayberry Place in Oregon, Ohio.

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



**Citation and Notification of Penalty**

**Company Name:** Mike Krueger, dba Altogether Roofing, LLC  
**Inspection Site:** 3359 Stonebrooke Ln., Maumee, OH 43537

---

Mike Krueger dba Altogether Roofing, LLC, was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.501(b)(13)), which was contained in OSHA Inspection #1257585, Citation number 1, Item number 1, and was affirmed as a final order on November 6, 2017, with respect to a workplace located at 2638 Spring Water Drive in Toledo, Ohio.

Mike Krueger dba Altogether Roofing, LLC, was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.501(b)(13)), which was contained in OSHA Inspection #1229800, Citation number 1, Item number 2, and was affirmed as a final order on January 24, 2018, with respect to a workplace located at 9520 Jerusalem Road in Curtice, Ohio.

Mike Krueger dba Altogether Roofing, LLC, was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.501(b)(13)), which was contained in OSHA Inspection #1177422, Citation number 2, Item number 2a, and was affirmed as a final order on March 3, 2017, with respect to a workplace located at 10429 White Oak Drive in Perrysburg, Ohio.

In accordance with 29 CFR 1903.19(d), abatement certification is required for this violation (using the CERTIFICATION OF CORRECTIVE ACTION WORKSHEET), and in addition, documentation demonstrating that abatement is complete must be included with your certification. This documentation may include, but is not limited to, evidence of the purchase or repair of the equipment, photographic or video evidence, or written records.

**ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM**

Date By Which Violation Must be Abated:	December 13, 2022
Proposed Penalty:	\$95,718.00



**Citation and Notification of Penalty**

**Company Name:** Mike Krueger, dba Altogether Roofing, LLC  
**Inspection Site:** 3359 Stonebrooke Ln., Maumee, OH 43537

---

Citation 2 Item 3 Type of Violation: **Willful - Serious**

29 CFR 1926.1053(b)(1): Where portable ladders are used for access to an upper landing surface and the ladder's length allows, the ladder side rails did not extend at least 3 feet (.9 m) above the upper landing surface being accessed:

Mike Krueger dba Altogether Roofing, LLC does not ensure the side rails of three portable aluminum extension ladders are extended at least three feet above the landing surface. Eight employees were exposed to falls from approximately 12 feet or greater from the top of the second (roof) level to the decking below while using the ladder to access the second (roof) level to perform residential roofing activities on a single-family home. This violation was most recently observed on or about June 22, 2022 at a jobsite located at 3359 Stonebrooke Ln. Maumee OH, 43537.

To abate this citation, the employer must demonstrate that portable ladder safety and proper usage training is provided and being used by its employees when accessing roofs and other elevated work surfaces while using portable ladders.

**U.S. Department of Labor**  
Occupational Safety and Health Administration

**Inspection Number:** 1603544  
**Inspection Date(s):** 06/22/2022 - 06/22/2022  
**Issuance Date:** 12/08/2022



**Citation and Notification of Penalty**

**Company Name:** Mike Krueger, dba Altogether Roofing, LLC  
**Inspection Site:** 3359 Stonebrooke Ln., Maumee, OH 43537

---

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.1053(b)(1)), which was contained in OSHA Inspection #1399714 (Repeat - Serious), Citation number 2, Item number 1, and was affirmed as a final order on November 7, 2019, with respect to a workplace located at 25368 Fox Hunt Drive in Perrysburg, Ohio.

Mike Krueger dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.1053(b)(1)), which was contained in OSHA Inspection #1177422 (Repeat - Serious), Citation number 2, Item number 2c, and was affirmed as a final order on March 3, 2017, with respect to a workplace located at 10429 White Oak Drive in Perrysburg, Ohio.

In accordance with 29 CFR 1903.19(d), abatement certification is required for this violation (using the CERTIFICATION OF CORRECTIVE ACTION WORKSHEET), and in addition, documentation demonstrating that abatement is complete must be included with your certification. This documentation may include, but is not limited to, evidence of the purchase or repair of the equipment, photographic or video evidence, or written records.

**ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM**

Date By Which Violation Must be Abated:	December 13, 2022
Proposed Penalty:	\$95,718.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.





**Citation and Notification of Penalty**

**Company Name:** Mike Krueger, dba Altogether Roofing, LLC  
**Inspection Site:** 3359 Stonebrooke Ln., Maumee, OH 43537

---

Citation 3 Item 1 Type of Violation: **Repeat - Serious**

29 CFR 1926.102(a)(1): The employer does not ensure that each affected employee uses appropriate eye or face protection when exposed to eye or face hazards from flying particles, molten metal, liquid chemicals, acids or caustic liquids, chemical gases or vapors, or potentially injurious light radiation:

On or about June 22, 2022 the employer Mike Krueger dba Altogether Roofing, LLC at jobsite located at 3359 Stonebrooke Ln. Maumee OH, 43537 does not ensure that each affected employee used appropriate eye or face protection when performing roofing work on a two story single family residential home while exposed to potential struck by hazards (flying particles/debris) while using pneumatic nail guns.

To abate this violation, the employer must provide evidence demonstrating that appropriate eye and face protection is selected and utilized during roofing and other construction activities.


Mike Krueger, dba Altogether Roofing, LLC was previously cited for a violation of this Occupational Safety and Health Standard (29 CFR 1926.102(a)(1)), which was contained in OSHA Inspection #1399714, Citation number 3, Item number 1a, and was affirmed as a final order on November 7, 2019, with respect to a workplace located at 25368 Fox Hunt Drive in Perrysburg, Ohio.

In accordance with 29 CFR 1903.19(d), abatement certification is required for this violation (using the CERTIFICATION OF CORRECTIVE ACTION WORKSHEET), and in addition, documentation demonstrating that abatement is complete must be included with your certification. This documentation may include, but is not limited to, evidence of the purchase or repair of the equipment, photographic or video evidence, or written records.

**ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM**

Date By Which Violation Must be Abated:  
Proposed Penalty:

December 13, 2022  
\$8,204.00

  
For  
Todd Jensen  
Area Director

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

**U.S. Department of Labor**  
Occupational Safety and Health Administration  
100 N. Summit Street  
Suite 100  
Toledo, OH 43604



---

## INVOICE / DEBT COLLECTION NOTICE

---

**Company Name: Mike Krueger, dba Altogether Roofing, LLC**  
**Inspection Site: 3359 Stonebrooke Ln., Maumee, OH 43537**  
**Issuance Date: 12/08/2022**

Summary of Penalties for Inspection Number: 1603544

Citation 1 Item 1, Serious	\$4,786.00
Citation 2 Item 1a, Willful - Serious	\$95,718.00
Citation 2 Item 1b, Willful - Serious	\$0.00
Citation 2 Item 2, Willful - Serious	\$95,718.00
Citation 2 Item 3, Willful - Serious	\$95,718.00
Citation 3 Item 1, Repeat - Serious	\$8,204.00

**TOTAL PROPOSED PENALTIES: \$300,144.00**

To avoid additional charges, please remit payment promptly to this Area Office for the total amount of the uncontested penalties summarized above. Make your check or money order payable to: "DOL-OSHA". Please indicate OSHA's Inspection Number (indicated above) on the remittance. You can also make your payment electronically at [www.pay.gov](http://www.pay.gov). At the top of the pay.gov homepage, type "OSHA" in the Search field and select Search. From the **OSHA Penalty Payment Form** search result, select Continue. The direct link is: <https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>. You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$25,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will cash the check or money order as if these restrictions or conditions do not exist.

If a personal check is issued, it will be converted into an electronic fund transfer (EFT). This means that our bank will copy your check and use the account information on it to electronically debit your account for the amount of the check. The debit from your account will then usually occur within 24 hours and will be shown on your regular account statement. You will not receive your original check back. The bank will destroy your original check, but


will keep a copy of it. If the EFT cannot be completed because of insufficient funds or closed account, the bank will attempt to make the transfer up to two times.

Pursuant to the Debt Collection Act of 1982 (Public Law 97-365) and regulations of the U.S. Department of Labor (29 CFR Part 20), the Occupational Safety and Health Administration is required to assess interest, delinquent charges, and administrative costs for the collection of delinquent penalty debts for violations of the Occupational Safety and Health Act.

**Interest:** Interest charges will be assessed at an annual rate determined by the Secretary of the Treasury on all penalty debt amounts not paid within one month (30 calendar days) of the date on which the debt amount becomes due and payable (penalty due date). The current interest rate is one percent (1%). Interest will accrue from the date on which the penalty amounts (as proposed or adjusted) become a final order of the Occupational Safety and Health Review Commission (that is, 15 working days from your receipt of the Citation and Notification of Penalty), unless you file a notice of contest. Interest charges will be waived if the full amount owed is paid within 30 calendar days of the final order.

**Delinquent Charges:** A debt is considered delinquent if it has not been paid within one month (30 calendar days) of the penalty due date or if a satisfactory payment arrangement has not been made. If the debt remains delinquent for more than 90 calendar days, a delinquent charge of six percent (6%) per annum will be assessed accruing from the date that the debt became delinquent.

**Administrative Costs:** Agencies of the Department of Labor are required to assess additional charges for the recovery of delinquent debts. These additional charges are administrative costs incurred by the Agency in its attempt to collect an unpaid debt. Administrative costs will be assessed for demand letters sent in an attempt to collect the unpaid debt.



\_\_\_\_\_  
For  
Todd Jensen  
Area Director

12/08/2022

\_\_\_\_\_  
Date