

U.S. Department of Labor Occupational Safety and Health Administration
53 Pleasant Street
Room 3901, J.C. Cleveland Federal Bldg.
Concord, NH 03301



02/21/2023

Ridge Runner Construction, LLC
and its successors
38 Old Chester Road
Derry, NH 03038

Dear Employer:

Enclosed you will find citations for violations of the Occupational Safety and Health Act of 1970 (the Act) which may have accompanying proposed penalties. Also enclosed is a booklet entitled, "Employer Rights and Responsibilities Following an OSHA Inspection", (OSHA 3000-04R) revised 2018, which explains your rights and responsibilities under the Act. If you have any questions about the enclosed citations and penalties, I would welcome further discussions in person or by telephone. Please contact me at (603) 225-1629.

You will note on page 6 of the booklet that, for violations which you do not contest, you must (1) notify this office promptly by letter that you have taken appropriate corrective action within the time set forth on the citation; and (2) pay any penalties assessed. Please inform me of the abatement steps you have taken and of their dates together with adequate supporting documentation; e.g., drawings or photographs of corrected conditions, purchase/work orders related to abatement actions, air sampling results. This information will allow us to close the case.

As indicated on page 3 of the booklet, you may request an informal conference with me during the 15-working-day notice of contest period. During such an informal conference you may present any evidence or views which you believe would support an adjustment to the citation or the penalty.

If you are considering a request for an informal conference to discuss any issues related to this Citation and Notification of Penalty, you must take care to schedule it early enough to allow time to contest after the informal conference, should you decide to do so. Please keep in mind that a written letter of intent to contest must be submitted to the Area Director within 15 working days of your receipt of the citation. The running of this contest period is not interrupted by an informal conference.

If you decide to request an informal conference, please complete the attached notice at the bottom of this letter and post it next to the Citations as soon as the time, date and the place of the informal conference have been determined. Be sure to bring to the conference with you any and all supporting documentation of existing conditions as well as of any abatement steps taken thus far. If conditions warrant, we can enter into an informal settlement agreement which amicably resolves this matter without litigation or contest.

You should be aware that OSHA publishes information on its inspection and citation activity on the Internet under the provisions of Electronic Freedom of Information Act. The information related to these alleged violations will be posted when our system indicates that you have received this citation. You are encouraged to review the information concerning your establishment at www.osha.gov. If you have any dispute with the accuracy of the information displayed, please contact this office.

Sincerely,

Joseph LaRose
Area Director

Enclosures

U.S. Department of Labor

Occupational Safety and Health Administration
53 Pleasant Street
Room 3901, J.C. Cleveland Federal Bldg.
Concord, NH 03301



Citation and Notification of Penalty

To:
Ridge Runner Construction, LLC
and its successors
38 Old Chester Road
Derry, NH 03038

Inspection Number: 1621825
Inspection Date(s): 09/14/2022 - 09/14/2022
Issuance Date: 02/21/2023

Inspection Site:
31 Captain Bannon Circle
Merrimack, NH 03054

The violation(s) described in this Citation and Notification of Penalty is (are) alleged to have occurred on or about the day(s) the inspection was made unless otherwise indicated within the description given below.

This Citation and Notification of Penalty (this Citation) describes violations of the Occupational Safety and Health Act of 1970. The penalty(ies) listed herein is (are) based on these violations. You must abate the violations referred to in this Citation by the dates listed and pay the penalties proposed, unless within 15 working days (excluding weekends and Federal holidays) from your receipt of this Citation and Notification of Penalty **you either call to schedule an informal conference (see paragraph below) or** you mail a notice of contest to the U.S. Department of Labor Area Office at the address shown above. Please refer to the enclosed booklet (OSHA 3000) which outlines your rights and responsibilities and which should be read in conjunction with this form. Issuance of this Citation does not constitute a finding that a violation of the Act has occurred unless there is a failure to contest as provided for in the Act or, if contested, unless this Citation is affirmed by the Review Commission or a court.

Posting - The law requires that a copy of this Citation and Notification of Penalty be posted immediately in a prominent place at or near the location of the violation(s) cited herein, or, if it is not practicable because of the nature of the employer's operations, where it will be readily observable by all affected employees. This Citation must remain posted until the violation(s) cited herein has (have) been abated, or for 3 working days (excluding weekends and Federal holidays), whichever is longer.

Informal Conference - An informal conference is not required. However, if you wish to have such a conference you may request one with the Area Director during the 15 working day contest period by calling (603) 225-1629. During such an informal conference, you may present any evidence or views which you believe would support an adjustment to the citation(s) and/or penalty(ies).

If you are considering a request for an informal conference to discuss any issues related to this Citation and Notification of Penalty, you must take care to schedule it early enough to allow time to contest after the informal conference, should you decide to do so. Please keep in mind that a written letter of intent to contest must be submitted to the Area Director within 15 working days of your receipt of this Citation. The running of this contest period is not interrupted by an informal conference.

If you decide to request an informal conference, please complete, remove and post the Notice to Employees next to this Citation and Notification of Penalty as soon as the time, date, and place of the informal conference have been determined. Be sure to bring to the conference any and all supporting documentation of existing conditions as well as any abatement steps taken thus far. If conditions warrant, we can enter into an informal settlement agreement which amicably resolves this matter without litigation or contest.

Right to Contest – You have the right to contest this Citation and Notification of Penalty. You may contest all citation items or only individual items. You may also contest proposed penalties and/or abatement dates without contesting the underlying violations. **Unless you inform the Area Director in writing that you intend to contest the citation(s) and/or proposed penalty(ies) within 15 working days after receipt, the citation(s) and the proposed penalty(ies) will become a final order of the Occupational Safety and Health Review Commission and may not be reviewed by any court or agency.**

Penalty Payment – Penalties are due within 15 working days of receipt of this notification unless contested. (See the enclosed booklet and the additional information provided related to the Debt Collection Act of 1982.) Make your check or money order payable to “DOL-OSHA”. Please indicate the Inspection Number on the remittance. You can also make your payment electronically at www.pay.gov. At the top of the [pay.gov](http://www.pay.gov) homepage, type "OSHA" in the Search field and select Search. From **OSHA Penalty Payment Form** search result, select Continue. The direct link is:

<https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>

You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$25,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will process the payments as if these restrictions or conditions do not exist.

Notification of Corrective Action – For each violation which you do not contest, you must provide **abatement certification** to the Area Director of the OSHA office issuing the citation and identified above. This abatement certification is to be provided by letter within 10 calendar days after each abatement date. Abatement certification includes the date and method of abatement. If the citation indicates that the violation was corrected during the inspection, no abatement certification is required for that item. The abatement certification letter must be posted at the location where the violation appeared and the corrective action took place or employees must otherwise be effectively informed about abatement activities. A sample abatement certification letter is enclosed with this Citation. In addition, where the citation indicates that **abatement documentation** is necessary, evidence of the purchase or repair of equipment, photographs or video, receipts, training records, etc., verifying that abatement has occurred is required to be provided to the Area Director.

Employer Discrimination Unlawful – The law prohibits discrimination by an employer against an

employee for filing a complaint or for exercising any rights under this Act. An employee who believes that he/she has been discriminated against may file a complaint no later than 30 days after the discrimination occurred with the U.S. Department of Labor Area Office at the address shown above.

Employer Rights and Responsibilities – The enclosed booklet (OSHA 3000) outlines additional employer rights and responsibilities and should be read in conjunction with this notification.

Notice to Employees – The law gives an employee or his/her representative the opportunity to object to any abatement date set for a violation if he/she believes the date to be unreasonable. The contest must be mailed to the U.S. Department of Labor Area Office at the address shown above and postmarked within 15 working days (excluding weekends and Federal holidays) of the receipt by the employer of this Citation and Notification of Penalty.

Inspection Activity Data – You should be aware that OSHA publishes information on its inspection and citation activity on the Internet under the provisions of the Electronic Freedom of Information Act. The information related to these alleged violations will be posted when our system indicates that you have received this citation. You are encouraged to review the information concerning your establishment at www.osha.gov. If you have any dispute with the accuracy of the information displayed, please contact this office.



NOTICE TO EMPLOYEES OF INFORMAL CONFERENCE

An informal conference has been scheduled with OSHA to discuss the citation(s) issued on 02/21/2023. The conference will be held by telephone or at the OSHA office located at 53 Pleasant Street, Room 3901, J.C. Cleveland Federal Bldg., Concord, NH 03301 on

_____ at _____. Employees and/or representatives of employees have a right to attend an informal conference.

CERTIFICATION OF CORRECTIVE ACTION WORKSHEET

Inspection Number: 1621825

Company Name: Ridge Runner Construction, LLC
Inspection Site: 31 Captain Bannon Circle, Merrimack, NH 03054
Issuance Date: 02/21/2023

List the specific method of correction for each item on this citation in this package that does not read "Corrected During Inspection" and return to: **U.S. Department of Labor – Occupational Safety and Health Administration, 53 Pleasant Street, Room 3901, J.C. Cleveland Federal Bldg., Concord, NH 03301.**

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

I certify that the information contained in this document is accurate and that the affected employees and their representatives have been informed of the abatement.

Signature

Date

Typed or Printed Name

Title

NOTE: 29 USC 666(g) whoever knowingly makes any false statements, representation or certification in any application, record, plan or other documents filed or required to be maintained pursuant to the Act shall, upon conviction, be punished by a fine of not more than \$10,000 or by imprisonment of not more than 6 months or both.

POSTING: A copy of completed Corrective Action Worksheet should be posted for employee review



Citation and Notification of Penalty

Company Name: Ridge Runner Construction, LLC
Inspection Site: 31 Captain Bannon Circle, Merrimack, NH 03054

The alleged violations below have been grouped because they involve similar or related hazards that may increase the potential for injury or illness.

Citation 1 Item 1 a Type of Violation: **Serious**

29 CFR 1926.20(b)(2): The employer did not initiate and maintain programs which provided for frequent and regular inspections of the job site, materials and equipment to be made by a competent person(s).

Jobsite - On or about September 14, 2022, the employer did not perform frequent and regular site inspections by a competent person where employees were exposed to falls and ladder hazards.

To abate this violation, the employer must implement a program which provides for frequent and regular inspections of their job sites, materials and equipment made by a competent person to identify and correct hazards.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	March 03, 2023
Proposed Penalty:	\$6,875.00

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1621825
Inspection Date(s): 09/14/2022 - 09/14/2022
Issuance Date: 02/21/2023



Citation and Notification of Penalty

Company Name: Ridge Runner Construction, LLC
Inspection Site: 31 Captain Bannon Circle, Merrimack, NH 03054

Citation 1 Item 1 b Type of Violation: **Serious**

29 CFR 1926.200(h)(1): Accident prevention tags were not used as a temporary means of warning employees of an existing hazard.

Jobsite - On or about September 14, 2022, a damaged and defective lifeline for a personal fall arrest system was installed on the roof and available for employee use, where it should have been tagged to warn employees of the hazard and removed from service.

Date By Which Violation Must be Abated:
Proposed Penalty:

Corrected During Inspection
\$0.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1621825
Inspection Date(s): 09/14/2022 - 09/14/2022
Issuance Date: 02/21/2023



Citation and Notification of Penalty

Company Name: Ridge Runner Construction, LLC
Inspection Site: 31 Captain Bannon Circle, Merrimack, NH 03054

Citation 1 Item 1 c Type of Violation: **Serious**

29 CFR 1926.452(m)(1): Crawling boards did not extend from the roof peak to the eaves when used in connection with roof construction, repair, or maintenance:

Jobsite - On or about September 14, 2022, an employee performing roofing work used a crawling board on the roof that did not extend from the roof peak to the eave. The approximately 8-foot section was in the middle of the roof deck where it was approximately 2 feet short of the peak and approximately 6 feet short of the eave .

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	March 03, 2023
Proposed Penalty:	\$0.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1621825
Inspection Date(s): 09/14/2022 - 09/14/2022
Issuance Date: 02/21/2023



Citation and Notification of Penalty

Company Name: Ridge Runner Construction, LLC
Inspection Site: 31 Captain Bannon Circle, Merrimack, NH 03054

Citation 1 Item 1 d Type of Violation: **Serious**

29 CFR 1926.452(m)(2): Crawling boards were not secured to the roof by ridge hooks or by means that met equivalent criteria (e.g., strength and durability).

Jobsite - On or about September 14, 2022, an employee used a crawling board on the roof that was not secured to the roof by ridge hooks or other adequate means. The approximately 8-foot section was secured at the base by a bundle of shingles at the ridge of a dormer and had no ridge hooks on it.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	March 03, 2023
Proposed Penalty:	\$0.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: Ridge Runner Construction, LLC
Inspection Site: 31 Captain Bannon Circle, Merrimack, NH 03054

The alleged violations below have been grouped because they involve similar or related hazards that may increase the potential for injury or illness.

Citation 1 Item 2 a Type of Violation: **Serious**

29 CFR 1926.503(a)(1): The employer did not provide a training program for each employee potentially exposed to fall hazards to enable each employee to recognize the hazards of falling and the procedures to be followed in order to minimize these hazards.

Jobsite - On or about September 14, 2022, the employer did not provide effective training to each employee exposed to fall hazards that enabled them to recognize the hazards of falling or the procedures to be followed to minimize those hazards. Employees exposed to falls of between approximately 9 and 20 feet were not utilizing fall protection and also installing lifelines by nailing through the rope and into the ridge beam in lieu of installing anchors.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	March 03, 2023
Proposed Penalty:	\$6,875.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1621825
Inspection Date(s): 09/14/2022 - 09/14/2022
Issuance Date: 02/21/2023



Citation and Notification of Penalty

Company Name: Ridge Runner Construction, LLC
Inspection Site: 31 Captain Bannon Circle, Merrimack, NH 03054

Citation 1 Item 2 b Type of Violation: **Serious**

29 CFR 1926.1060(a):The employer did not provide a training program for each employee using ladders and stairways, as necessary, which would enable each employee to recognize hazards related to ladders and stairways and train each employee in the procedures to be followed to minimize these hazards.

Jobsite - On or about September 14, 2022, the employer did not provide training to each employee using ladders where employees were exposed to falls of between approximately 9 and 20 feet using an access ladder that was not extended at least 3 feet above the upper landing surface.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	March 03, 2023
Proposed Penalty:	\$0.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: Ridge Runner Construction, LLC
Inspection Site: 31 Captain Bannon Circle, Merrimack, NH 03054

Citation 2 Item 1 Type of Violation: **Repeat - Serious**

29 CFR 1926.1053(b)(1): Where portable ladders were used for access to an upper landing surface and the ladder's length allows, the ladder side rails did not extend at least 3 feet (.9 m) above the upper landing surface being accessed.

The employer routinely fails to ensure effective protections against falls as required by the standard, as demonstrated on September 14, 2022, when employees were utilizing a ladder at a jobsite located at 31 Captain Bannon Circle in Merrimack, NH that was not extended at least 3 feet above the upper landing surface and exposed to falls of between approximately 9 and 20 feet.

- a. Jobsite - On or about September 14, 2022, the aluminum extension ladder being used by employees for access to the roof at the front of the house was not extended at least 3 feet above the landing surface, exposing the employees to a fall of approximately 9 feet to the porch roof and approximately 20 feet to the ground below.
- b. Jobsite - On or about September 14, 2022, the aluminum extension ladder set up on the front of the garage did not extend at least 3 feet above the landing surface where it was resting on the fascia board.
- c. Jobsite - On or about September 14, 2022, the aluminum extension ladder set up on the back of the garage did not extend at least 3 feet above the landing surface where it was resting on the fascia board.
- d. Jobsite - On or about September 14, 2022, the aluminum extension ladder set up on the left side of the house on the gable did not extend at least 3 feet above the landing surface.

The employer routinely fails to ensure effective protections against falls as required by the standard, as demonstrated on September 14, 2022, when employees were utilizing a ladder at a jobsite located at 31 Captain Bannon Circle in Merrimack, NH that was not extended at least 3 feet above the upper landing surface and exposed to falls of between approximately 9 and 20 feet.

To abate this violation, the employer must ensure that all ladders used by employees for access to an upper level are extended at least 3 feet above that upper level.

Pursuant to 29 CFR 1903.19, the employer must submit documents describing the steps it is taking to ensure compliance, including an explanation of how these steps protect employees from fall hazards when using ladders.

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1621825
Inspection Date(s): 09/14/2022 - 09/14/2022
Issuance Date: 02/21/2023



Citation and Notification of Penalty

Company Name: Ridge Runner Construction, LLC
Inspection Site: 31 Captain Bannon Circle, Merrimack, NH 03054

Ridge Runner Construction, LLC was previously cited for a violation of this occupational safety and health standard 29 CFR 1926.1053(b)(1), which was contained in OSHA inspection number 1230187, citation number 1, item number 4 and was affirmed as a final order on June 8, 2018, with respect to a workplace located at 131 Lynnfield St. in Peabody, MA.

Date By Which Violation Must be Abated:
Proposed Penalty:

Corrected During Inspection
\$13,750.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: Ridge Runner Construction, LLC
Inspection Site: 31 Captain Bannon Circle, Merrimack, NH 03054

Citation 3 Item 1 Type of Violation: **Willful - Serious**

29 CFR 1926.501(b)(13): Each employee(s) engaged in residential construction activities 6 feet (1.8 m) or more above lower levels were not protected by guardrail systems, safety net system, or personal fall arrest system, nor were employee(s) provided with an alternative fall protection measure under another provision of paragraph 1926.501 (b).

The employer fails to ensure effective protections against falls as required by the standard, as demonstrated on September 14, 2022, when employees were performing roofing activities at a jobsite located at 31 Captain Bannon Circle in Merrimack, NH without fall protections and were exposed to falls of between approximately 9 feet and 20 feet.

Jobsite - On or about September 14, 2022, employees unloading bundles of shingles on the roof of a two story home were not protected from falls of approximately 9 feet to the porch roof and 20 feet to the ground where fall protection was not utilized.

To abate this violation, the employer must ensure that all employees use complete personal fall arrest, guardrail, or safety net systems when an employee performs construction work 6 feet or more above a lower level.

Pursuant to 29 CFR 1903.19, the employer must submit documents describing the steps it is taking to ensure compliance, including an explanation of how these steps protect employees from fall hazards.

Ridge Runner Construction, LLC was previously cited for a repeat violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.501(b)(11), which was contained in OSHA inspection number 1501441, citation number 1, item number and was affirmed as a final order on October 4, 2021, with respect to a workplace located at 105 Haverhill St. in North Reading, MA.

Ridge Runner Construction, LLC was previously cited for a violation of this occupational safety and health standard 29 CFR 1926.501(b)(13), which was contained in OSHA inspection number 1230187, citation number 1, item number 2 and was affirmed as a final order on June 8, 2018, with respect to a workplace located at 131 Lynnfield St. in Peabody, MA.

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1621825
Inspection Date(s): 09/14/2022 - 09/14/2022
Issuance Date: 02/21/2023



Citation and Notification of Penalty

Company Name: Ridge Runner Construction, LLC
Inspection Site: 31 Captain Bannon Circle, Merrimack, NH 03054

Date By Which Violation Must be Abated:
Proposed Penalty:

Corrected During Inspection
\$68,754.00

Joseph LaRose
Area Director

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration
53 Pleasant Street
Room 3901, J.C. Cleveland Federal Bldg.
Concord, NH 03301



INVOICE / DEBT COLLECTION NOTICE

Company Name: Ridge Runner Construction, LLC
Inspection Site: 31 Captain Bannon Circle, Merrimack, NH 03054
Issuance Date: 02/21/2023

Summary of Penalties for Inspection Number: 1621825

Citation 1 Item 1a, Serious	\$6,875.00
Citation 1 Item 1b, Serious	\$0.00
Citation 1 Item 1c, Serious	\$0.00
Citation 1 Item 1d, Serious	\$0.00
Citation 1 Item 2a, Serious	\$6,875.00
Citation 1 Item 2b, Serious	\$0.00
Citation 2 Item 1, Repeat - Serious	\$13,750.00
Citation 3 Item 1, Willful - Serious	\$68,754.00

TOTAL PROPOSED PENALTIES: **\$96,254.00**

To avoid additional charges, please remit payment promptly to this Area Office for the total amount of the uncontested penalties summarized above. Make your check or money order payable to: "DOL-OSHA". Please indicate OSHA's Inspection Number (indicated above) on the remittance. You can also make your payment electronically at www.pay.gov. At the top of the [pay.gov](http://www.pay.gov) homepage, type "OSHA" in the Search field and select Search. From the **OSHA Penalty Payment Form** search result, select Continue. The direct link is: <https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>. You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$25,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will cash the check or money order as if these restrictions or conditions do not exist.

If a personal check is issued, it will be converted into an electronic fund transfer (EFT). This means that our bank will copy your check and use the account information on it to electronically debit your account for the amount of the check. The debit from your account will then usually occur within 24 hours and will be shown on your regular

account statement. You will not receive your original check back. The bank will destroy your original check, but will keep a copy of it. If the EFT cannot be completed because of insufficient funds or closed account, the bank will attempt to make the transfer up to two times.

Pursuant to the Debt Collection Act of 1982 (Public Law 97-365) and regulations of the U.S. Department of Labor (29 CFR Part 20), the Occupational Safety and Health Administration is required to assess interest, delinquent charges, and administrative costs for the collection of delinquent penalty debts for violations of the Occupational Safety and Health Act.

Interest: Interest charges will be assessed at an annual rate determined by the Secretary of the Treasury on all penalty debt amounts not paid within one month (30 calendar days) of the date on which the debt amount becomes due and payable (penalty due date). The current interest rate is one percent (1%). Interest will accrue from the date on which the penalty amounts (as proposed or adjusted) become a final order of the Occupational Safety and Health Review Commission (that is, 15 working days from your receipt of the Citation and Notification of Penalty), unless you file a notice of contest. Interest charges will be waived if the full amount owed is paid within 30 calendar days of the final order.

Delinquent Charges: A debt is considered delinquent if it has not been paid within one month (30 calendar days) of the penalty due date or if a satisfactory payment arrangement has not been made. If the debt remains delinquent for more than 90 calendar days, a delinquent charge of six percent (6%) per annum will be assessed accruing from the date that the debt became delinquent.

Administrative Costs: Agencies of the Department of Labor are required to assess additional charges for the recovery of delinquent debts. These additional charges are administrative costs incurred by the Agency in its attempt to collect an unpaid debt. Administrative costs will be assessed for demand letters sent in an attempt to collect the unpaid debt.

Joseph LaRose

Area Director

Date