

U.S. Department of Labor Occupational Safety and Health Administration
1000 South Pine Island Road
Suite 100
Fort Lauderdale, FL 33324



12/27/2023

Stucco Works Inc.
and its successors
17240 SW 296 STREET
Homestead, FL 33030

Dear Employer:

Enclosed you will find citations for violations of the Occupational Safety and Health Act of 1970 (the Act) which may have accompanying proposed penalties. Also enclosed is a booklet entitled, "Employer Rights and Responsibilities Following an OSHA Inspection", (OSHA 3000-04R) revised 2018, which explains your rights and responsibilities under the Act. If you have any questions about the enclosed citations and penalties, I would welcome further discussions in person or by telephone. Please contact me at (954) 424-0242.

You will note on page 6 of the booklet that, for violations which you do not contest, you must (1) notify this office promptly by letter that you have taken appropriate corrective action within the time set forth on the citation; and (2) pay any penalties assessed. Please inform me of the abatement steps you have taken and of their dates together with adequate supporting documentation; e.g., drawings or photographs of corrected conditions, purchase/work orders related to abatement actions, air sampling results. This information will allow us to close the case.

As indicated on page 3 of the booklet, you may request an informal conference with me during the 15-working-day notice of contest period. During such an informal conference you may present any evidence or views which you believe would support an adjustment to the citation or the penalty.

If you are considering a request for an informal conference to discuss any issues related to this Citation and Notification of Penalty, you must take care to schedule it early enough to allow time to contest after the informal conference, should you decide to do so. Please keep in mind that a written letter of intent to contest must be submitted to the Area Director within 15 working days of your receipt of the citation. The running of this contest period is not interrupted by an informal conference.

If you decide to request an informal conference, please complete the attached notice at the bottom of this letter and post it next to the Citations as soon as the time, date and the place of the informal conference have been determined. Be sure to bring to the conference with you any and all supporting documentation of existing conditions as well as of any abatement steps taken thus far. If conditions warrant, we can enter into an informal settlement agreement which amicably resolves this matter without litigation or contest.

You should be aware that OSHA publishes information on its inspection and citation activity on the Internet under the provisions of Electronic Freedom of Information Act. The information related to these alleged violations will be posted when our system indicates that you have received this citation. You are encouraged to review the information concerning your establishment at www.osha.gov. If you have any dispute with the accuracy of the information displayed, please contact this office.

Sincerely,

Condell Eastmond
Area Director

Enclosures

U.S. Department of Labor

Occupational Safety and Health Administration
1000 South Pine Island Road
Suite 100
Fort Lauderdale, FL 33324



Citation and Notification of Penalty

To:
Stucco Works Inc.
and its successors
17240 SW 296 STREET
Homestead, FL 33030

Inspection Number: 1683379
Inspection Date(s): 07/13/2023 - 12/27/2023
Issuance Date: 12/27/2023

Inspection Site:
1096 N Venetian Drive
Miami Beach, FL 33139

The violation(s) described in this Citation and Notification of Penalty is (are) alleged to have occurred on or about the day(s) the inspection was made unless otherwise indicated within the description given below.

This Citation and Notification of Penalty (this Citation) describes violations of the Occupational Safety and Health Act of 1970. The penalty(ies) listed herein is (are) based on these violations. You must abate the violations referred to in this Citation by the dates listed and pay the penalties proposed, unless within 15 working days (excluding weekends and Federal holidays) from your receipt of this Citation and Notification of Penalty **you either call to schedule an informal conference (see paragraph below) or** you mail a notice of contest to the U.S. Department of Labor Area Office at the address shown above. Please refer to the enclosed booklet (OSHA 3000) which outlines your rights and responsibilities and which should be read in conjunction with this form. Issuance of this Citation does not constitute a finding that a violation of the Act has occurred unless there is a failure to contest as provided for in the Act or, if contested, unless this Citation is affirmed by the Review Commission or a court.

Posting - The law requires that a copy of this Citation and Notification of Penalty be posted immediately in a prominent place at or near the location of the violation(s) cited herein, or, if it is not practicable because of the nature of the employer's operations, where it will be readily observable by all affected employees. This Citation must remain posted until the violation(s) cited herein has (have) been abated, or for 3 working days (excluding weekends and Federal holidays), whichever is longer.

Informal Conference - An informal conference is not required. However, if you wish to have such a conference you may request one with the Area Director during the 15 working day contest period by calling (954) 424-0242. During such an informal conference, you may present any evidence or views which you believe would support an adjustment to the citation(s) and/or penalty(ies).

If you are considering a request for an informal conference to discuss any issues related to this Citation and Notification of Penalty, you must take care to schedule it early enough to allow time to contest after the informal conference, should you decide to do so. Please keep in mind that a written letter of intent to contest must be submitted to the Area Director within 15 working days of your receipt of this Citation. The running of this contest period is not interrupted by an informal conference.

If you decide to request an informal conference, please complete, remove and post the Notice to Employees next to this Citation and Notification of Penalty as soon as the time, date, and place of the informal conference have been determined. Be sure to bring to the conference any and all supporting documentation of existing conditions as well as any abatement steps taken thus far. If conditions warrant, we can enter into an informal settlement agreement which amicably resolves this matter without litigation or contest.

Right to Contest – You have the right to contest this Citation and Notification of Penalty. You may contest all citation items or only individual items. You may also contest proposed penalties and/or abatement dates without contesting the underlying violations. **Unless you inform the Area Director in writing that you intend to contest the citation(s) and/or proposed penalty(ies) within 15 working days after receipt, the citation(s) and the proposed penalty(ies) will become a final order of the Occupational Safety and Health Review Commission and may not be reviewed by any court or agency.**

Penalty Payment – Penalties are due within 15 working days of receipt of this notification unless contested. (See the enclosed booklet and the additional information provided related to the Debt Collection Act of 1982.) Make your check or money order payable to “DOL-OSHA”. Please indicate the Inspection Number on the remittance. You can also make your payment electronically at www.pay.gov. At the top of the pay.gov homepage, type "OSHA" in the Search field and select Search. From **OSHA Penalty Payment Form** search result, select Continue. The direct link is:

<https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>

You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$25,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will process the payments as if these restrictions or conditions do not exist.

Notification of Corrective Action – For each violation which you do not contest, you must provide **abatement certification** to the Area Director of the OSHA office issuing the citation and identified above. This abatement certification is to be provided by letter within 10 calendar days after each abatement date. Abatement certification includes the date and method of abatement. If the citation indicates that the violation was corrected during the inspection, no abatement certification is required for that item. The abatement certification letter must be posted at the location where the violation appeared and the corrective action took place or employees must otherwise be effectively informed about abatement activities. A sample abatement certification letter is enclosed with this Citation. In addition, where the citation indicates that **abatement documentation** is necessary, evidence of the purchase or repair of equipment, photographs or video, receipts, training records, etc., verifying that abatement has occurred is required to be provided to the Area Director.

Employer Discrimination Unlawful – The law prohibits discrimination by an employer against an employee for filing a complaint or for exercising any rights under this Act. An employee who believes that

he/she has been discriminated against may file a complaint no later than 30 days after the discrimination occurred with the U.S. Department of Labor Area Office at the address shown above.

Employer Rights and Responsibilities – The enclosed booklet (OSHA 3000) outlines additional employer rights and responsibilities and should be read in conjunction with this notification.

Notice to Employees – The law gives an employee or his/her representative the opportunity to object to any abatement date set for a violation if he/she believes the date to be unreasonable. The contest must be mailed to the U.S. Department of Labor Area Office at the address shown above and postmarked within 15 working days (excluding weekends and Federal holidays) of the receipt by the employer of this Citation and Notification of Penalty.

Inspection Activity Data – You should be aware that OSHA publishes information on its inspection and citation activity on the Internet under the provisions of the Electronic Freedom of Information Act. The information related to these alleged violations will be posted when our system indicates that you have received this citation. You are encouraged to review the information concerning your establishment at www.osha.gov. If you have any dispute with the accuracy of the information displayed, please contact this office.



NOTICE TO EMPLOYEES OF INFORMAL CONFERENCE

An informal conference has been scheduled with OSHA to discuss the citation(s) issued on 12/27/2023. The conference will be held by telephone or at the OSHA office located at 1000 South Pine Island Road, Suite 100, Fort Lauderdale, FL 33324 on _____ at _____.

Employees and/or representatives of employees have a right to attend an informal conference.

CERTIFICATION OF CORRECTIVE ACTION WORKSHEET

Inspection Number: 1683379

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139
Issuance Date: 12/27/2023

List the specific method of correction for each item on this citation in this package that does not read "Corrected During Inspection" and return to: **U.S. Department of Labor – Occupational Safety and Health Administration, 1000 South Pine Island Road, Suite 100, Fort Lauderdale, FL 33324.**

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

I certify that the information contained in this document is accurate and that the affected employees and their representatives have been informed of the abatement.

Signature

Date

Typed or Printed Name

Title

NOTE: 29 USC 666(g) whoever knowingly makes any false statements, representation or certification in any application, record, plan or other documents filed or required to be maintained pursuant to the Act shall, upon conviction, be punished by a fine of not more than \$10,000 or by imprisonment of not more than 6 months or both.

POSTING: A copy of completed Corrective Action Worksheet should be posted for employee review.



Citation and Notification of Penalty

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139

Citation 1 Item 1 Type of Violation: **Serious**

29 CFR 1910.1200(e)(1): The employer did not develop, implement, and/or maintain at the workplace a written hazard communication program which describes how the criteria specified in 29 CFR 1910.1200(f), (g), and (h) will be met: (as incorporated by reference under 29 CFR 1926.59):

On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, the employer did not develop, implement, and/or maintain at the workplace a written hazard communication program for hazardous chemicals used such as, but not limited to cement material containing silica, exposing employees to eye and/or face burn/abrasion injuries when working with mixing cement and performing stucco work.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	January 24, 2024
Proposed Penalty:	\$3,572.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1683379
Inspection Date(s): 07/13/2023 - 12/27/2023
Issuance Date: 12/27/2023



Citation and Notification of Penalty

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139

Citation 1 Item 2 Type of Violation: **Serious**

29 CFR 1926.20(b)(1): The employer did not initiate and maintain such programs as may be necessary to comply with this part:

On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, the employer did not implement an accident prevention program for employees involved in stucco work, exposing employees to fall, struck by, crushed by and burn hazards.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	January 24, 2024
Proposed Penalty:	\$6,250.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139

Citation 1 Item 3 Type of Violation: **Serious**

29 CFR 1926.451(b)(1): Each platform on all working levels of scaffolds was not fully planked or decked between the front uprights and the guardrail supports as specified in paragraphs 1926.451(b)(1)(i)-(ii):

- a) On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the north side of house, the scaffold system was not fully planked, exposing employees to a 10-foot fall hazard.
- b) On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the north side of house, the scaffold system was not fully planked, exposing employees to a 27-foot fall hazard.
- c) On or about June 29, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the west side of the house, the scaffold system was not fully planked, exposing employees to a 12-foot fall hazard.
- d) On or about June 29, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the west side of the house, the scaffold system was not fully planked, exposing employees to an 18-foot fall hazard.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated: January 24, 2024
Proposed Penalty: \$6,250.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1683379
Inspection Date(s): 07/13/2023 - 12/27/2023
Issuance Date: 12/27/2023



Citation and Notification of Penalty

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139

Citation 1 Item 4 Type of Violation: **Serious**

29 CFR 1926.451(c)(2): Supported scaffold poles, legs, posts, frames, or uprights did not bear on base plates and mud sills or other adequate firm foundation:

On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the north side of the house, the scaffold system lacked base plates, exposing employees to a fall, struck by and/or crushed by hazard.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated: January 24, 2024
Proposed Penalty: \$6,250.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139

Citation 1 Item 5 Type of Violation: **Serious**

29 CFR 1926.451(e)(1): Scaffold platforms were more than 2 feet (0.6 m) above or below a point of access, portable ladders, hook-on ladders, attachable ladders, stair towers (scaffold stairways/towers), stairway-type ladders (such as ladder stands), ramps, walkways, integral prefabricated scaffold access, or direct access from another scaffold, structure, personnel hoist, or similar surface shall be used. Cross braces shall not be used as a means of access.

- a) On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the north side of the house, the scaffold system did not have a ladder, exposing employees to a 10-foot fall hazard.
- b) On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the north side of the house, the scaffold system did not have a ladder, exposing employees to a 27-foot fall hazard.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated: January 24, 2024
Proposed Penalty: \$6,250.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1683379
Inspection Date(s): 07/13/2023 - 12/27/2023
Issuance Date: 12/27/2023



Citation and Notification of Penalty

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139

Citation 1 Item 6 Type of Violation: **Serious**

29 CFR 1926.451(f)(1): Scaffold and/or scaffold components were loaded in excess of their maximum intended loads or rated capacities, whichever was less:

On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the north side of the house, the scaffold system was overloaded in that the hoist/pulley on the scaffold system was missing a coupling pin, exposing employees to struck by and/or crushed by hazard.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	January 24, 2024
Proposed Penalty:	\$15,625.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1683379
Inspection Date(s): 07/13/2023 - 12/27/2023
Issuance Date: 12/27/2023



Citation and Notification of Penalty

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139

Citation 1 Item 7 Type of Violation: **Serious**

29 CFR 1926.451(f)(3): Scaffold and scaffold components were not inspected for visible defects by a competent person before each work shift and after any occurrence which could affect a scaffold's structural integrity:

- a) On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the north side of the house, the scaffold system was not inspected by a competent person, exposing employees to a fall, struck by and/or crushed by hazard.
- b) On or about June 29, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the west side of the house, the scaffold system was not inspected by a competent person, exposing employees to a fall, struck by and/or crushed by hazard.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	January 24, 2024
Proposed Penalty:	\$6,250.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139

Citation 1 Item 8 Type of Violation: **Serious**

29 CFR 1926.451(g)(1): 29 CFR 1926.451(g)(1): Each employee on a scaffold more than 10 feet (3.1m) above a lower level was not protected from falling to that lower level by fall protection established in accordance with paragraphs (g)(1)(i) through (vii) of this section:

- a) On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the north side of the house, the scaffold system had a cross brace as the guardrail, but it was missing a top rail, exposing employees to a 10-foot fall hazard.
- b) On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the north side of the house, the scaffold system had a cross brace as the guardrail, but it was missing a top rail, exposing employees to a 27-foot fall hazard.
- c) On or about June 29, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the west side of the house, the scaffold system had a cross brace as the guardrail, but it was missing a top rail, exposing employees to a 12-foot fall hazard.
- d) On or about June 29, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the west side of the house, the scaffold system had a cross brace as the guardrail, but it was missing a top rail, exposing employees to a 18-foot fall hazard.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated: January 24, 2024
Proposed Penalty: \$6,250.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139

Citation 1 Item 9 Type of Violation: **Serious**

29 CFR 1926.451(h)(1): Each employee on a scaffold was not provided with additional protection from falling hand tools, debris, and other small objects through the installation of toe boards, screens, guardrail systems, or through the erection of debris nets, catch platforms, or canopy structures that contain or deflect the falling objects. For falling objects too large, heavy or massive to be contained or deflected, the employer did not place and secure such potential falling objects away from the edge of the surface from which they could fall:

- a) On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the north side of the house, the scaffold system did not have a toeboard, exposing employees below to a struck-by hazard.
- b) On or about June 29, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, west side of the house, the scaffold system did not have a toeboard, exposing employees below to a struck-by hazard.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	January 24, 2024
Proposed Penalty:	\$6,250.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139

Citation 1 Item 10 b Type of Violation: **Serious**

29 CFR 1926.454(b): The employer did not have each employee who was involved in erecting, disassembling, moving, operating, repairing, maintaining, or inspecting a scaffold trained by a competent person to recognize any hazards associated with the work in question:

On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the north side of the house, the scaffold system was erected by employees that were not adequately trained to erect the scaffold, exposing employees to a fall, struck by and/or crushed by hazard.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	January 24, 2024
Proposed Penalty:	\$0.00

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1683379
Inspection Date(s): 07/13/2023 - 12/27/2023
Issuance Date: 12/27/2023



Citation and Notification of Penalty

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139

Citation 1 Item 11 Type of Violation: **Serious**

29 CFR 1926.502(b)(3): Guardrail systems were not capable of withstanding, without failure, a force of at least 200 pounds (890 N) applied within 2 inches (5.1 cm) of the top edge, in any outward or downward direction, at any point along the top edge:

On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the north side of the house, the second level of the house had a wood guardrail system that was not strong enough to withstand the required weight, exposing employees to a 17-foot fall hazard.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	January 24, 2024
Proposed Penalty:	\$4,465.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1683379
Inspection Date(s): 07/13/2023 - 12/27/2023
Issuance Date: 12/27/2023



Citation and Notification of Penalty

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139

Citation 2 Item 1 Type of Violation: **Other-than-Serious**

29 CFR 1926.25(a): During the course of construction, alteration, or repairs, form and scrap lumber with protruding nails, and all other debris was not kept cleared from work areas, passageways, and stairs, in and around buildings or other structures:

On or about July 13, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, on the north side of the house, the yard area was cluttered with equipment, tools and debris.

Date By Which Violation Must be Abated: January 24, 2024
Proposed Penalty: \$0.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1683379
Inspection Date(s): 07/13/2023 - 12/27/2023
Issuance Date: 12/27/2023



Citation and Notification of Penalty

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139

Citation 2 Item 2 Type of Violation: **Other-than-Serious**

29 CFR 1904.29(b)(3): The employer did not enter each recordable injury or illness on the OSHA 300 Log and 301 Incident Report within seven (7) calendar days of receiving information that a recordable injury or illness has occurred:

On or about October 4, 2023, at 1096 N Venetian Drive, Miami Beach, Florida, 33139, the employer had not recorded on the OSHA 300 an incident that resulted in a work-related fatality on July 13, 2023.

Date By Which Violation Must be Abated:
Proposed Penalty:

January 24, 2024
\$893.00

Condell Eastmond
Area Director

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration
1000 South Pine Island Road
Suite 100
Fort Lauderdale, FL 33324



INVOICE / DEBT COLLECTION NOTICE

Company Name: Stucco Works Inc.
Inspection Site: 1096 N Venetian Drive, Miami Beach, FL 33139
Issuance Date: 12/27/2023

Summary of Penalties for Inspection Number: 1683379

Citation 1 Item 1, Serious	\$3,572.00
Citation 1 Item 2, Serious	\$6,250.00
Citation 1 Item 3, Serious	\$6,250.00
Citation 1 Item 4, Serious	\$6,250.00
Citation 1 Item 5, Serious	\$6,250.00
Citation 1 Item 6, Serious	\$15,625.00
Citation 1 Item 7, Serious	\$6,250.00
Citation 1 Item 8, Serious	\$6,250.00
Citation 1 Item 9, Serious	\$6,250.00
Citation 1 Item 10a, Serious	\$6,250.00
Citation 1 Item 10b, Serious	\$0.00
Citation 1 Item 11, Serious	\$4,465.00
Citation 2 Item 1, Other-than-Serious	\$0.00
Citation 2 Item 2, Other-than-Serious	\$893.00

TOTAL PROPOSED PENALTIES: **\$74,555.00**

To avoid additional charges, please remit payment promptly to this Area Office for the total amount of the uncontested penalties summarized above. Make your check or money order payable to: "DOL-OSHA". Please indicate OSHA's Inspection Number (indicated above) on the remittance. You can also make your payment electronically at www.pay.gov. At the top of the pay.gov homepage, type "OSHA" in the Search field and select Search. From the **OSHA Penalty Payment Form** search result, select Continue. The direct link is: <https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>. You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$25,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will cash the check or money order as if these

restrictions or conditions do not exist.

If a personal check is issued, it will be converted into an electronic fund transfer (EFT). This means that our bank will copy your check and use the account information on it to electronically debit your account for the amount of the check. The debit from your account will then usually occur within 24 hours and will be shown on your regular account statement. You will not receive your original check back. The bank will destroy your original check, but will keep a copy of it. If the EFT cannot be completed because of insufficient funds or closed account, the bank will attempt to make the transfer up to two times.

Pursuant to the Debt Collection Act of 1982 (Public Law 97-365) and regulations of the U.S. Department of Labor (29 CFR Part 20), the Occupational Safety and Health Administration is required to assess interest, delinquent charges, and administrative costs for the collection of delinquent penalty debts for violations of the Occupational Safety and Health Act.

Interest: Interest charges will be assessed at an annual rate determined by the Secretary of the Treasury on all penalty debt amounts not paid within one month (30 calendar days) of the date on which the debt amount becomes due and payable (penalty due date). The current interest rate is one percent (1%). Interest will accrue from the date on which the penalty amounts (as proposed or adjusted) become a final order of the Occupational Safety and Health Review Commission (that is, 15 working days from your receipt of the Citation and Notification of Penalty), unless you file a notice of contest. Interest charges will be waived if the full amount owed is paid within 30 calendar days of the final order.

Delinquent Charges: A debt is considered delinquent if it has not been paid within one month (30 calendar days) of the penalty due date or if a satisfactory payment arrangement has not been made. If the debt remains delinquent for more than 90 calendar days, a delinquent charge of six percent (6%) per annum will be assessed accruing from the date that the debt became delinquent.

Administrative Costs: Agencies of the Department of Labor are required to assess additional charges for the recovery of delinquent debts. These additional charges are administrative costs incurred by the Agency in its attempt to collect an unpaid debt. Administrative costs will be assessed for demand letters sent in an attempt to collect the unpaid debt.

Condell Eastmond

Area Director

Date